

Town of Wappinger – Fire Inspector

20 Middlebush Rd., NY 12590

Phone # 845-297-1373 / Fax # 845-297-0579

- APPLICATION FOR FIRE ALARM PERMIT -

(Fee \$250)

FIRE ALARM PERMITS REQUIRE TWO (2) SETS OF PLANS BE SUBMITTED WITH THIS APPLICATION

APP.#: _____ FA#: _____ Receipt # _____

CHECK #: _____ CASH : _____ AMOUNT PAID : _____

DATE : _____ GRID #: _____

JOB SITE ADDRESS:

OWNERS NAME:

ADDRESS: _____

TEL#: _____

INSTALLATION CO. NAME : _____

ADDRESS: _____

TEL. #: _____ LICENSE# _____

FIRE ALARM – PLEASE LIST NUMBER OF DEVICES: FIRE ALARM/SECURITY SYSTEM PANEL: _____

PANELS: _____ TOTAL NO. OF SECURITY SYSTEM DEVICES BEING INSTALLED: _____

ANNUNCIATORS: _____

SMOKE/HEAT DETECTORS: _____

HORNS / STROBES: _____

MANUAL PULL STATIONS: _____

OTHERS: _____

TOTAL: _____

NO WORK MAY BE PERFORMED UNTIL A PERMIT IS ISSUED

The owner of the property covered by this application and the undersigned applicant agree:

To conform to all applicable laws of this jurisdiction and the applicant is responsible for scheduling inspections with an electrical agency approved by the Town of Wappinger.

The applicant swears that they have been specifically authorized by the owner to execute this application.

APPLICANT'S SIGNATURE: _____

FIRE INSPECTOR: _____ DATE: _____

FIRE ALARM PERMIT:

FC907.1.1 Construction documents

Construction documents for fire alarm systems shall be of sufficient clarity to indicate the location, nature and extent of the work proposed and show in detail that it will conform to the provisions of this code, the International Building Code and relevant laws, ordinances, rules and regulations, as determined by the fire code official.

FC907.1.2 Fire alarm shop drawings

Shop drawings for fire alarm system shall be submitted for review and approval prior to system installation, and shall include, but not be limited to, all of the following where applicable to the system being installed:

1. A floor plan that indicates the use of all rooms
2. Locations of alarm-initiating devices.
3. Locations of alarm notification appliances, including candela ratings for visible alarm notification appliances.
4. Design minimum audibility level for occupant notification.
5. Location of fire alarm control unit, transponders and notification power supplies.
6. Annunciators
7. Power connection
8. Battery calculations
9. Conductor type and sizes
10. Voltage drop calculations
11. Manufacturers' data sheets indicating model numbers and listing
12. Details of ceiling height and construction
13. The interface of fire safety control functions.
14. Classification of the supervising station.