

Fire Inspector:
Howard Prager - Ext. 127


TOWN OF WAPPINGER

Supervisor:
Richard Thurston

Chelsea Fire District:
Yvonne Tompkins - Chair Person
James Tompkins


Hughsonville Fire District:
Bruce Flower
Robert Scott Bostwick

New Hackensack Fire District:
Roger Munoz
Chris Heady



FIRE PREVENTION BUREAU

20 MIDDLEBUSH ROAD
WAPPINGERS FALLS, NY 12590
PH: 845-297-1373
Fax: 845-297-0579
hprager@townofwappingerny.gov



Date: 5-12-23
Project Name: Chelsea Ridge Wastewater Treatment Plant
Location: 85 Popula Blvd.
Grid No: 6056-01-468615
Address: 85 Popula Blvd.

We have reviewed the above referenced project and submit the following comments to the Planning Board:

- ☐ NO COMMENTS: Project meets with our approval.
- ☐ Road Names need to be submitted to the Fire Inspector for approval
- ☒ The following items need to be addressed:

Comments: Need access for emergency equipment
in going to and around bldg.
If need be, put a gate and Knox box or
Knox lock on gate

Date: 6/13/23

Signature: Jm Tompkins
Fire Prevention Bureau Member