



**COUNTY OF DUTCHESS**

DEPARTMENT OF BEHAVIORAL & COMMUNITY HEALTH

January 22, 2024

Bea Ogunti, Planning Secretary  
Town of Wappinger Planning Board  
20 Middlebush Road  
Wappingers Falls, NY 12590

Re: Randolph School Sugar Shacks and Lean To's - SEQR  
Tax Map #135689-6157-01-216814  
Town of Wappinger

Dear Ms. Ogunti:

The following is in response to your submission to this office consisting of SEQR information for the above project.

1. This Department has no objection to the Town Planning Board serving as the lead agent for SEQR.
2. Mapping shows one of the proposed structures partially on top of the existing sewage disposal systems. The septic system must be carefully staked out such that no structures are installed over the existing system.
3. If this project constitutes an increase in water/sewage usage or if any of the proposed structures will have water/sewer use, detailed plans and specifications must be submitted to this Department by a New York State licensed professional for review of the sewage collection/disposal and water systems. Reference is made to Dutchess County Sanitary Code Articles 5 and 19.

Should you find that we can be of assistance, please contact us at 486-3404.

Very truly yours,

A handwritten signature in black ink, appearing to read "D. Keeler", is written over a horizontal line.

Daniel J. Keeler, P.E.  
Senior Public Health Engineer  
Environmental Health Services

cc: File 128402  
Tara Grogan, DC Planning

- 85 Civic Center Plaza – Suite 106, Poughkeepsie, NY 12601 - (845) 486-3404
  - Millbrook District Office - 131 County House Road, Millbrook, NY 12545 - (845) 677-4001
  - Beacon District Office - 223 Main Street, Beacon, NY 12508 - (845) 838-4801
- [ehs@dutchessny.gov](mailto:ehs@dutchessny.gov) [www.dutchessny.gov](http://www.dutchessny.gov)