



**DUTCHESS COUNTY GOVERNMENT**  
**DEPARTMENT OF BEHAVIORAL & COMMUNITY HEALTH**

February 14, 2024

Bea Ogunti, Planning Secretary  
Town of Wappinger Planning Board  
20 Middlebush Road  
Wappingers Falls, NY 12590

Re: Village Crest Apartments Site Plan for Laundry/Gym Buildings - SEQR  
Tax Map #135689-6259-02-635855, 705840  
Town of Wappinger

Dear Ms. Ogunti:

The following is in response to your submission to this office consisting of SEQR information for the above project.

1. This Department has no objection to the Town Planning Board serving as the lead agent for SEQR.
2. Detailed plans and specifications must be submitted to this Department by a New York State licensed professional for review of the proposed exterior sewage collection and water distribution systems. Reference is made to Dutchess County Sanitary Code Articles 5 and 19.
3. If any increase in water usage is proposed, the above-referenced submission must also demonstrate adequate capacity of the water supply and sewage collection/treatment systems.

Should you find that we can be of assistance, please contact us at 486-3404.

Very truly yours,

A handwritten signature in black ink, appearing to read "D. Keeler", with a stylized flourish at the end.

Daniel J. Keeler, P.E.  
Senior Public Health Engineer  
Environmental Health Services

cc: File 128467  
William H. Povall III, P.E.