

GENERAL CONSTRUCTION CHECKLIST

OWNER: JACQUELYN NALITT
 APPLICANT: GOODWILL INDUSTRIES
 LOCATION: TOWN OF WAPPINGER
 TYPE OF WORK: PROPOSED RETAIL STORE REHABILITATION WORK

REVIEWED BY: TOWN OF WAPPINGER'S BUILDING DEPT.
 DATE: 8/18/97
 WITHIN FIRE LIMITS:
 () YES 770.2(C)
 (X) NO 770.2(D)


PLANS DESIGNED BY: TACONIC DESIGN CONSULTANTS

No	TOPIC	CODE SECTION	REQUIRED OR ALLOWED	ACTUAL
1	OCCUPANCY PROPOSED FIRE HAZARD CLASS	701.4 702	C2 MODERATE	C2 MODERATE
2	CONSTRUCTION TYPE	704.1	TYPE 2B	TYPE 2B
3	HEIGHT AND FIRE AREA BASIC AREA BASIC HEIGHT ACCESSIBILITY SPRINKLER INCREASE	705.4 TABLES 705 TABLES 705 705.5B 705.5C	3 STORIES 15,000 SF * UNLIMITED 21,500 SF 60,000 SF	1 STORY 25,560 SF 17'± 25,560 SF 25,560 SF
* FIRE AREA OF A ONE-STORY BUILDING MAY BE UNLIMITED PROVIDED THAT THE BUILDING IS LOCATED OUTSIDE THE FIRE LIMITS, HAS OPEN UNOBSTRUCTED SPACE ON ALL SIDE ACCESSIBLE FOR FIRE FIGHTING, AS SET FORTH IN SECTION 705.5 (B)(1) OF THIS PART AND SUCH SPACE SHALL BE AT LEAST 50 FEET WIDE.				
4	EXTERIOR FIRE SPREAD DISTANCE SEPARATION CONSTRUCTION LIMITS PARTY WALLS FINISHES	PART 770 TB I-770 770.2C & D 770.6 770.8	0' TYPE 2B NON-COMBUSTIBLE COMBUSTIBLE	0' TYPE 2B NON-COMBUSTIBLE COMBUSTIBLE
5	INTERIOR FIRE SPREAD FIRE SEPARATION MIXED OCCUPANCY OPENINGS FIRE STOPPING	PART 771 TB II-771 771.4A6 771.41 771.5C	3 HOURS N/A N/A N/A	3 HOURS + N/A N/A N/A
6	SPACE REQUIREMENTS CEILING HEIGHT	762.3 762.4	8'	14'±
7	LIGHT AND VENTILATION ARTIFICIAL LIGHT NATURAL LIGHT VENTILATION	763 763.1 763.2 763.3	AS-REQUIRED AS-REQUIRED AS-REQUIRED	AS-REQUIRED AS-REQUIRED AS-REQUIRED
8	SPECIAL STAIRS	764.1	N/A	N/A
9a	EXITS NUMBER ONE EXIT PERMITTED UNITS OF EXIT WIDTH DISTANCE OF TRAVEL DEAD END CORRIDOR ENCLOSURE CORRIDOR WIDTH DOOR WIDTH DOOR SWING SMOKE STOPS OPENING PROTECTIVES PANIC HARDWARE DOOR ALARMS	765.8 TB X-765 TB VI-765 765.1J TB III-704 TB I-765 TB V-765 765.5A1 765.2A TB III-771 765.5A4 1060.9A	N/A N/A 200' N/A 60" / 44" 44" SWING OUT N/A N/A AS-REQUIRED AS-REQUIRED	N/A N/A 71' N/A 60" / 44" 44" SWING OUT N/A N/A AS-REQUIRED AS-REQUIRED
9b	STAIRWAYS ACCESS TO ROOF DIMENSIONS COMBUSTIBLE STAIRS HANDRAILS	765.4 765.4A TB IV-765 765.4B2 765.4C3 765.4A11	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
10	SAFETY GLAZING	766.1	N/A	N/A
11	GARAGE AND PARKING STRUCTURES	767	N/A	N/A
12	MALLS AND PASSAGEWAYS PASSAGEWAYS MALLS	768.1 768.2	N/A N/A	N/A N/A
13	ATRIUMS	769	N/A	N/A
14	INTERIOR FINISH	772.2	A OR B	A OR B
15	PLASTIC MATERIALS	PART 773 PART 1120	N/A AS-REQUIRED	N/A AS-REQUIRED

No	TOPIC	CODE SECTION	REQUIRED OR ALLOWED	ACTUAL
16	FIRE PROTECTION EQUIP FIRE ALARM SYSTEM ZONED SYSTEM BATTERY BACKUP PULL BOX TRAVEL FIRE DEPT CONNECTION DETECTION SYSTEM SPRINKLER SYSTEM STANDPIPE SYSTEM YARD HYDRANTS WATCHMAN SYSTEM AUTO VENT ALARM COORDINATED FIRE SAFETY	774.2 1060.2A5 1060.2D1 TB I-1060 774.1B 774.3 774.4 774.5 774.6 774.7 774.8 774.9	N/A N/A N/A N/A N/A N/A AS-REQUIRED N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A PRE-EXISTING N/A N/A N/A N/A N/A
17	SPECIAL HAZARDS AREAS OF PUB. ASSEMB. FIRE AND SMOKE DET. SPRINKLER SYSTEM GAS PUMPS EMERGENCY VENTILATION FAN SHUTDOWN EXHAUST HOOD SYSTEM LIST OTHER SPECIAL HAZARDS:	791 792 774.10 1004.2F 1004.2E 1064.2B N/A	N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A
18	DESIGN LOADS SNOW FLOOR WIND	803.3 TB III-803 TB V-803 TB VI-803	35 PSF 100 PSF AS-REQUIRED	PRE-EXISTING PRE-EXISTING PRE-EXISTING
19	PLUMBING FIXTURES MATERIALS FREEZING ROOF DRAINAGE	900.2 904.6 850.7 TB VI-903	AS-REQUIRED AS-REQUIRED AS-REQUIRED	AS-REQUIRED AS-REQUIRED PRE-EXISTING
20	HEAT PRODUCING EQUIP. PROHIBITED LOCATIONS ENCLOSURE AIR SUPPLY VENTS AND CHIMNEYS PROHIBITED USES OUTLET LOCATION	1000.2D 771.4J 1000.2C 1005.2 TB I-1005	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
21	ELECTRICAL METAL VENEERS EMERGENCY POWER EMERGENCY LIGHTS EXIT LIGHTS	NEC 1030.1G 1032.2 TB I-1032 1033	N/A AS-REQUIRED N/A ALL (C2)	N/A AS-REQUIRED AS SHOWN AS-REQUIRED
22	ACCESSIBILITY EXTERIOR FACILITIES INTERIOR ROUTES INTERIOR ELEMENTS AREAS OF REFUGE ASSEMBLY SPACE SPECIFIC OCCUPANCIES	A117.1-92 1101.1 1101.3 1101.4 1101.5C 1101.6 1102	AS-REQUIRED AS-REQUIRED AS-REQUIRED N/A N/A AS-REQUIRED	PRE-EXISTING AS-REQUIRED AS-REQUIRED N/A N/A AS-REQUIRED
23	ENERGY REQUIREMENTS CERTIFICATION	ENERGY CODE 7810.10	AS-REQUIRED	AS-REQUIRED

Goodwill Industries

OF GREATER NEW YORK INC.



4-21 27th AVE., ASTORIA, NY 11102 * (718) 777-6329 * FAX (718) 721-1739

I. DESIGN LOADS (N/A)
 FLOOR: PRE-EXISTING 4" CONC. SLAB
 ROOF: PRE-EXISTING ROOF SYSTEM

II. STEEL FRAMING
 STEEL FRAMING MATERIALS AND WORK SHALL BE IN CONFORMANCE WITH ASTM & AISI STANDARDS FOR NON-BEARING PARTITIONS.

III. CODES
 A. ALL MATERIALS, SYSTEMS, AND METHODS OF CONSTRUCTION SHALL CONFORM WITH CURRENT EDITION OF THE NEW YORK STATE CODES AND APPLICABLE TOWN AND COUNTY LAWS, ORDINANCES, RULES AND REGULATIONS.
 B. ELECTRICAL SERVICE SHALL BE 200 AMP/220 VOLT.
 C. ALL PLUMBING, HEATING AND ELECTRICAL WORK SHALL BE IN CONFORMANCE WITH STATE AND LOCAL CODES.

FILE COPY

RECEIVED
AUG 27 1997

APPROVED
AUG 28 1997

[Signature]
FIRE INSPECTOR
TOWN OF WAPPINGER

RECEIVED
AUG 28 1997
97-568
Building Inspector
FIRE INSPECTOR
TOWN OF WAPPINGER

GOODWILL INDUSTRIES
OF GREATER NEW YORK INC.
WAPPINGER PLAZA
TOWN OF WAPPINGER, NEW YORK

TACONIC DESIGN CONSULTANTS
1227 ROUTE 300
NEWBURGH, N.Y. 12550
SUITE #3
(914) 567-9061
(914) 567-0677 (fax#)

GENERAL NOTES

DATE: 8/18/97 SCALE: AS NOTED REVISED:

ENGINEER: CHARLES T. BROWN, PE. DRAWN BY: DAVE

JOB NUMBER: 97173 SHEET 1 OF 4 A-1

97-568
16011