



NOTES:
EXISTING ENTRANCE
CHANGE TO EXIT

WORK THESE
AREAS ONLY

NOTES:
CUT EXISTING BULKHEAD
AS REQUIRED
INSTALL 42" X 90"
ENTRANCE DOOR
MATCH EXISTING STORE FRONT

- 1) Illuminated exit light and directional exit light where indicated
- 2) Replace and duplicate emergency lighting
- 3) All doors to smoke areas to be of proper fire rating
- 4) All exterior curb spanning thru drop ceiling to be replaced with fire electrical outlets.
- 5) Exit door shown in gate area closed off
- 6) New exit door to be shown in foot of garage and to meet requirements of exit requirements
- 7) Storage above entrance & exit to be grated to prevent water from falling on exit of main set to back exit sign

ARCHITECT: T. ERCOLANO
VERONA, NJ 012338

93-72
APPROVED *De Atchko*
MAR 12 1993
FIRE INSPECTOR
TOWN OF WAPPINGER
MAR 11 1993
RECEIVED
MAR 12 1993
RECEIVED
FIRE INSPECTOR
TOWN OF WAPPINGER
Building Inspector

HANNEL
STORE PLANNING

STORE # 375-G A	WAPPINGER FALLS, NY.
SCALE: 3/32" = 1'	DATE: 6/23/92
DRAWN BY: D. CLARKE	
TOTAL SQUARE FEET: 25560	
SELLING SQUARE FEET: 21114	
BULK PEN 5440	
FINAL DATE:	
REVISED: 11/20/92	1/25/93
11/24/92	1/29/93
12/8/92	3/9/93
1/21/93	CEILING 14' 0"